

**WEST METRO FIRE-RESCUE DISTRICT**

**SUPPLEMENTAL APPLICATION FOR A FIREWORKS LICENSE**

1. List the hours of operation (This can affect if emergency lighting is required and illuminated exit signage is required. This is required if opened after dusk.): \_\_\_\_\_  
\_\_\_\_\_
2. Submit a site plan to scale showing the following: Public ways, buildings, vehicle access and parking areas, clearance to combustibles, fire department access for buildings 150 feet, and fuel dispensing. Illustrate the distance from tent sales to closest buildings in area.
3. Submit a drawing of the size of the building or tent structure. This will play a factor in NFPA 1124 to determine if the structure complies with temporary or permanent structure requirements.
4. If in a permanent building, provide information on what type of fire protection is provided in the building? (i.e. sprinkler and fire alarm system) \_\_\_\_\_  
\_\_\_\_\_
5. Are the tent specifications Fire Retardant Certified?      **Yes**    **No**    **Not applicable**
6. Submit a floor plan of the area either to scale or showing the measurements for the following: location and type of fire extinguishers, floor plan, layout and height of displays (maximum 6 feet high, perimeter maximum 12 feet high), firebreaks, aisle width, construction details of tent (conforms to NFPA 102), fire exits, signage.
7. Submit information on Shelving. Indicate and provide detailed information on how and where the flame breaks will be located. How the shelving will be constructed. This information shall be indicated on the floor plan also.
8. How will the fireworks be secured while unoccupied and not open for business? \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
9. Show the ratings in the building construction to verify the NFPA 1124 requirements are met (especially fireworks storage areas). If a tent provide tent information.
10. You will be required to provide on all sides of exterior/interior of tent “NO FIREWORKS DISCHARGE WITHIN 300 FEET”; At each entrance, “FIREWORKS – NO SMOKING”; and EXIT signs.
11. Will you be using generators?      **Yes**    **No**    (If yes, are the generators limited to a 5-gallon fuel capacity and at least 20 feet from the tent. Indicate where the generator will be located on the site plan.)

12. Please estimate the quantity of fireworks that will be stored on the licensed premises. The total quantity of consumer fireworks on hand should not exceed 125 lb of pyrotechnic composition or, in a building protected throughout with an approved automatic sprinkler system installed in accordance with NFPA 13. Or where the actual weight of the pyrotechnic composition of consumer fireworks is not known, 25 percent of the gross weight of the consumer fireworks, including packaging, shall be permitted to be used to determine the weight of the composition. \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

12. Provide documentation on all personnel handling consumer fireworks that they received safety training related to the performance of their duties.

13. Make sure records are maintained on available inventory on the premises. This will be inspected upon final inspection.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

Contacts:

West Metro Fire-Rescue District  
Aaron Surratt, Fire Inspector (763) 537-2323 extension 2003  
Shelby Wolf, Fire Inspector (763) 537-2323 extension 2004

Valerie Leone, New Hope City Clerk(763) 531-5117