

WEST METRO FIRE-RESCUE DISTRICT FIREWORKS TENT COMPLIANCE CHECKLIST

PROPERTY ADDRESS _____

YES/NO/N/A	DESCRIPTION	NFPA #
	Permit/License for tent sales	7.3.1(b)
	If a tent conforms to NFPA 102	7.4.1(2)
	If a building it conforms to building construction type. Is there proper fire barriers and no penetrations through fire barriers. (Single buildings and multiple tenant buildings)	7.3.5
	Is there proper fire protection equipment in the building?	7.4.5
	Retail area for fireworks is within 150 feet of fire department access	7.6.1
	Area within 30 feet of retail area of fireworks is free of dry grass, brush, and combustibles	7.6.2
	No storage vehicle or trailer within 10 feet of retail area for fireworks.	7.6.3
	Retail area for fireworks is 20 feet from other buildings	7.7.2
	No smoking within 50 feet of retail area for fireworks	7.6.5.1
	Retail area for fireworks is 20 feet from combustibles	7.7.2
	Retail area for fireworks is 20 feet from other tents	7.7.2
	Fireworks shall not be ignited or discharged within 300 feet of the retail firework area.	7.6.4.1
	Retail area for fireworks is 10 feet from vehicle parking	7.7.2
	Retail area for fireworks is 50 feet from propane sales, gas pumps, above ground flammable liquids/gas tanks, natural gas facilities	7.7.3.1
	Tent is 300 feet from bulk storage or dispensing of flammable gas and liquids	7.7.3.2
	Sign on each side of exterior of tent, (letters 4 in. high), NO FIREWORKS DISCHARGE WITHIN 300 FEET	7.6.4.2
	Sign at each entrance, (letters 2 in. high), FIREWORKS - NO SMOKING	7.6.5.2
	Distance to any extinguisher no more than 35 feet	7.5.2.3.2
	One extinguisher - pressure water minimum 2A	7.5.2.2
	One extinguisher — dry chemical minimum 2A	7.5.2.2.2
	Tent shall have minimum of 2 exits	7.8.3.2
	Maximum distance to any exit is 75 feet	7.8.4.1
	Tent exit openings shall be a minimum of 44 inches wide	7.8.6.2
	Egress door that has a latching device shall be provide with panic hardware complying with NFPA 101.	7.3.14.4.2
	Means of egress doors shall be of the side-hinge swinging type and shall be arranged to swing in the direction of egress travel.	7.3.14.4.3
	Exits must be marked with approved exit signs (If open at dusk shall be illuminated with emergency lighting)	7.9.1.1
	Dead-end aisles not allowed	7.8.5.3.4

	Other required exits shall be located at, or within 10 ft of, the end of an aisle or a cross-aisle.	7.3.14.3.2.2
	Aisles shall terminate at an exit, another aisle, or cross-aisle.	7.3.14.3.2.3
	Aisles shall be minimum of 48 inches wide	7.8.5.1.1
	Aisles must remain unobstructed	7.8.5.1.2
	Where cross-aisles are required, not less than one cross-aisle shall have at least one end terminate at, or within 10 feet of, and exit.	7.3.14.3.2.7
	Height of Merchandise displays no higher than 6 feet	7.10.2
	Where located along the perimeter of the consumer fireworks retail sales area, the maximum height of sales displays shall be limited to 12 ft.	7.3.15.2.2
	Where continuous displays of consumer fireworks are located on shelving, cases, counters and similar fixtures, a flame break shall be provided so that the maximum distance between flame breaks does not exceed 16 ft where measured along the length of the display.	7.3.15.3.1
	<u>Freestanding displays shall be permitted without flame breaks</u> provided the dimensions of the area occupied by the fireworks merchandise do not exceed 4 feet in width, 8 feet in length, and 6 feet in height, and the displayed firework merchandise is separated from other displays of merchandise by aisles having a minimum clear width of 4 feet.	7.3.15.3.7
	No more than 32 feet of merchandise between flame breaks	7.10.3.1
	Is shelving meet appropriate requirements per NFPA 1124	7.3.15.4
	Are all fuses covered per NFPA 1124	7.3.15.5
	No consumer fireworks shall be displayed for sale or stored within 5 feet of any public/private entrance in an enclosed building or structure.	7.3.19.2.1
	Tent supervised 24 hours or secured while unoccupied or not opened	7.3.19.3
	Temporary electrical wiring must meet NFPA 70, NEC	7.11.1
	Is temporary wiring protected as required.	7.4.9.1
	Generators must be minimum 20 feet from tent	7.11.3.2
	Generator to be limited to 5 gallons fuel	7.11.3.3
	Is housekeeping ok	7.3.21
	Are records maintained on available inventory on the premises	7.3.24.1